

TECHNICAL BULLETIN

SUBJECT: VF 21/22 Housings with pre-blended fuel

DATE: December 22, 2006

Recent testing utilizing stock CC-21-7 and CC-22-7 coalescers indicates performance meeting API 1581 effluent criteria can be achieved at reduced flow rates when compared with fuel without FSII. The tests were performed on Category M type fuel in accordance with the specification and utilizing the S-LW criteria for 0.5% water maximum.

The recommended flow rates are:

VF21 using CC-21-7 coalescer 15 gpm
VF22 using CC-22-7 coalescer 22 gpm

Development continues on new coalescer models for pre-blended fuel that will allow higher flow rates.